


NITROGEN FRACTIONS


NITROGEN FRACTIONS

- Ammonia makes up to 60% to 75% of TKN.
- For measurement the nitrogen fractions directly, standard analysis of TKN on both filtered and unfiltered samples as well as standard analyses of ammonia need to be done.
- Nitrate/nitrite should be measured in influent wastewater only if a significant industrial source present or in side stream.




NITROGEN FRACTIONS SON

- Soluble inorganic nitrogen = ammonia + nitrate/nitrite
- Soluble organic nitrogen = filtered TKN - ammonia
- Particulate organic nitrogen = TKN - filtered TKN



NITROGEN FRACTIONS

NONBIODEGRADABLE PARTICULATE TKN



NITROGEN FRACTIONS

NONBIODEGRADABLE PARTICULATE TKN

Method-1

nbpON is associated with nbpCOD.
Calculate the fraction F_{upN}

$$F_{upN} = \frac{pTKN}{pCOD}$$


F_{upN} = N:COD ratio for un-biodegradable particulate COD

$$pTKN = (TKN - sON - NH_4_N)$$

$$\frac{nbpON}{nbpCOD} = \frac{pTKN}{pCOD}$$

$$nbpON = \frac{pTKN}{pCOD} \times nbpCOD$$

$$nbpON = F_{upN} \times (nbpCOD)$$



NITROGEN FRACTIONS

NONBIODEGRADABLE PARTICULATE TKN

Method-2

- nbpON is associated with nbVSS.
- nbpON can be estimated from VSS and nbVSS

$$pTKN = (TKN - sON - NH4_N)$$


$$fN = \frac{pTKN}{VSS}$$

fN= fraction of organic nitrogen in VSS , g N/g VSS

$$nbpON = fN \times (nbVSS)$$


$$\frac{nbpON}{nbVSS} = \frac{pTKN}{VSS}$$

$$nbpON = \frac{pTKN}{VSS} \times nbVSS$$



NITROGEN FRACTIONS


NON-BIODEGRADABLE SOLUBLE TKN(nbsON)



NITROGEN FRACTIONS


NON-BIODEGRADABLE SOLUBLE TKN(nbsON)

- Passes through the plant untouched.
- Estimated as approximately 1.5-2% of the Influent TKN. Typically ranges from 1 to 2 mg/l.
- Assuming that all of the soluble biodegradable organic nitrogen is degraded within the treatment process, then the effluent filtered TKN minus the effluent ammonia will equal the nbsON.



PHOSPHORUS FRACTIONS

- Knowing the phosphorus fractionation is important for plants that provide biological phosphorus removal.
- Orthophosphate(PO_4) and soluble biodegradable phosphorus are taken up by PAOs in the aerobic zone.
- Orthophosphate(PO_4) typically makes up a large portion of TP in domestic wastewater(50% to 80%).
- Almost all of the effluent soluble phosphorus is orthophosphate.
- P fractions are simplified as follows:
 - TP, total phosphorus .
 - Orthophosphate (PO_4) represents the two reactive fractions.




WASTEWATER CONSTITUENT RELATIONSHIPS


The relationships between various constituents in raw influent establish a frame of reference and are important for various process considerations. Established relationships can also be relied upon when data is non-existent. The typical wastewater constituent relationships are presented below.

Ratio	Typical Values	Meaning
COD/BOD	1.75-2.2	Indicates the component of organic matter that is biodegradable low : readily biodegradable organics high : slowly biodegradable
pCOD/VSS	1.6-1.8	Indicates the COD contents of the VSS
TSS/BOD	0.6-1.2	Indicates the solids content of wastewater
VSS/TSS	0.7-0.9	Identifies the inert suspended solids (ISS) fraction
TKN/BOD	0.18-0.24	Indicator of the ability to denitrify, as it demonstrates how much carbon is available for nitrate reduction If this number is high, supplemental carbon is usually required to sufficiently denitrify
TP/BOD	0.015-0.025	provides one approach for estimating the influent phosphorus concentration

RELATIONSHIP BETWEEN BOD,COD AND TSS



RELATIONSHIP BETWEEN BOD, COD, TSS, TN, & TP



EXAMPLE

SAMPLING RESULTS FOR WWTP IN JORDAN

No.	Parameter	unit	Plant Influent	Plant Effluent
1	Total COD	mg/L	1281	316
2	Filtered COD(1.2 um glass fiber filter)	mg/L	448	184
3	Flocculated & filtered COD (0.45 um filter)	mg/L	332	
4	BOD₅	mg/L	692	80
5	Filtered BOD₅(1.2 um glass fiber filter)	mg/L	274	32
6	TSS	mg/L	537	102
7	VSS	mg/L	444	83
8	Total Phosphorus	mg/L	15.8	15.6
9	Orthophosphate	mg/L	32	37
10	Total Kjeldhal Nitrogen(TKN)	mg/L	137	91
11	Filtered TKN	mg/L	103.6	81.6
12	Ammonium(NH₄-N)	mg/L	99.2	76.9
13	Nitrate	mg/L		2
14	Nitrite	mg/L		2
15	Alkalinity as CaCO₃	mg/L	619	581

EXAMPLE- ESTIMATION OF nbsCOD

No.	Parameter	unit	Plant Influent	Plant Effluent
1	Total COD	mg/L	1281	316
2	Filtered COD(1.2 um glass fiber filter)	mg/L	448	184
3	Flocculated & filtered COD(0.45 um filter)	mg/L	332	
4	BOD ₅	mg/L	692	80
5	Filtered BOD ₅ (1.2 um glass fiber filter)	mg/L	274	32

$nbsCOD = \text{Effluent Soluble COD (for very low soluble effluent BOD)}$

$nbsCOD = \text{Effluent Soluble COD} - \text{Effluent biodegradable soluble COD.}$

$$\frac{fCOD}{fBOD} = \frac{448}{274} = 1.64$$

bCOD in the effluent

$$bCOD_e = fBOD_e \times \frac{fCOD}{fBOD} = 32 \times 1.64 = 52.5 \text{ mg/l}$$

$$nbsCOD = 184 - 52.5 = 131.5 \text{ mg/l}$$

Influent & Effluent non-biodegradable soluble COD = 131.5 mg/l

$$F_{us} = \frac{131.5}{1281} = 0.10$$

		COD		COD Fractions	
nbpCOD	Xi			F _{up}	
Slowly Biodegradable COD (sbCOD)	Particulate			F _{xsp}	
	Colloidal			F _{xs}	
Readily Biodegradable COD (rbCOD)	SnVFA			F _{bs}	
	VFA				
nbsCOD	Sus	132		F _{us}	0.10
Total COD		1281			

EXAMPLE – ESTIMATION OF rbCOD

No.	Parameter	unit	Plant Influent	Plant Effluent
1	Total COD	mg/L	1281	316
2	Filtered COD(1.2 um glass fiber filter)	mg/L	448	184
3	Flocculated & filtered COD	mg/L	332	
4	BOD ₅	mg/L	692	80
5	Filtered BOD ₅ (1.2 um glass fiber filter)	mg/L	274	32

$rbCOD = ffCOD \text{ influent} - nbsCOD \text{ effluent}$

$$nbsCOD = 184 - 52.5 = 131.5 \text{ mg / l}$$

$$rbCOD = 332 - 131.5 = 200.5 \text{ _ mg / l}$$

$$F_{bs} = \frac{200.5}{1281} = 0.16$$

		COD	COD Fractions	
nbpCOD	Xi		F_{up}	
Slowly Biodegradable COD (sbCOD)	Particulate		F_{xsp}	
	Colloidal		F_{xs}	
Readily Biodegradable COD (rbCOD)	SnVFA	201	F_{bs}	0.16
	VFA			
nbsCOD	Sus	132	F_{us}	0.10
Total COD		1281		

PARTICULATE COD/VSS RATIO(F_{cv})

No.	Parameter	unit	Plant Influent	Plant Effluent
1	Total COD	mg/L	1281	316
2	Filtered COD(1.2 um glass fiber filter)	mg/L	448	184
7	VSS	mg/L	444	83

$$pCOD = tCOD - fCOD = 1281 - 448 = 834$$

$$VSS = 444$$

$$F_{cv} = \frac{834}{444} = 1.88 \quad \text{measured}$$

EXAMPLE – ESTIMATION OF nbpCOD & sbCOD

Influent COD fractions	Default	Estimate	Notes
Fbs	0.160	0.158	from Step 1
Fus	0.050	0.101	from Step 1
Fup	0.130	0.100	affects BOD, VSS
Fzbh	0.000	0.000	from separate method
Fxs	0.660	0.641	by difference (must be > 0!!)
Fxsp	0.750	0.800	affects VSS, scale: 0 to 1

Influent values	Measured (From Step 1)	Calculated (Based on fractions above)	Match Status
CODt	1281		
Soluble COD (GFC)	448	496	Acceptable
FF COD	332	332	Excellent
cBOD5	692	606	Acceptable
fcBOD5 (GFC)	274	259	Acceptable
VSS	444	418	Acceptable
TSS	537	511	Acceptable
Calculated concentrations (from CODt & fractions)			
Sus	130		
Xi	128		
Sbs	202		
Xs (c+p)	821		
Zbh	0		
Xsc	164	Added to Ss for BOD calcs	
Xsp	657		

		COD	COD Fractions	
nbpCOD	Xi		F _{up}	
Slowly Biodegradable COD (sbCOD)	Particulate		F _{xsp}	
	Colloidal		F _{xs}	
Readily Biodegradable COD (rbCOD)	SnVFA	201	F _{bs}	0.16
	VFA			
nbsCOD	Sus	132	F _{us}	0.10
Total COD		1281		

RESULTS FOR COD FRACTIONS FOR THE EXAMPLE

		COD		COD Fractions		
nbpCOD	Xi	128		F_{up}	0.10	
Slowly Biodegradable COD (sbCOD)	Particulate	657	821	F_{xsp}	0.80	0.64
	Colloidal	164		F_{xs}	0.20	
Readily Biodegradable COD (rbCOD)	SnVFA	202		F_{bs}	0.16	
	VFA					
nbsCOD	Sus	130		F_{us}	0.10	
Total COD		1281			1.00	

EXAMPLE – ESTIMATION OF nbVSS

$$nbVSS = \left[\left(\frac{nbpCOD}{pCOD} \right) \right] \times VSS$$

$$nbVSS = \left[\left(\frac{128.1}{657 + 128} \right) \right] \times 418.2 = 68.3$$

$$nbVSS = \left[\left(\frac{128.1}{784.8} \right) \right] \times 418.2 = 68.3$$


		COD		COD Fractions	
nbpCOD	Xi	128		F _{up}	0.10
Slowly Biodegradable COD (sbCOD)	Particulate	657	821	F _{xsp}	0.80
	Colloidal	164		F _{xs}	0.20
Readily Biodegradable COD (rbCOD)	SnVFA	202		F _{bs}	0.16
	VFA				
nbsCOD	Sus	130		F _{us}	0.10
Total COD		1281			1.00

EXAMPLE – ESTIMATION OF sON

No.	Parameter	unit	Plant Influent
10	Total Kjeldhal Nitrogen (TKN)	mg/L	137
11	Filtered TKN	mg/L	103.6
12	Ammonium(NH ₄ -N)	mg/L	99.2
13	Nitrate	mg/L	
14	Nitrite	mg/L	

$sON = fTKN - \text{ammonia}$

$sON = 103.6 - 99.2 = 4.4$



EXAMPLE – ESTIMATION OF nbpON

No.	Parameter	unit	Plant Influent
7	VSS	mg/L	444
10	Total Kjeldhal Nitrogen (TKN)	mg/L	137
11	Filtered TKN	mg/L	103.6
12	Ammonium(NH4-N)	mg/L	99.2
13	Nitrate	mg/L	
14	Nitrite	mg/L	

$$pTKN = (TKN - sON - NH_4_N)$$

$$pTKN = 137 - 103.6 = 33.4$$

$$fN = \frac{pTKN}{VSS}$$

$$fN = \frac{33.4}{444} = 0.075$$

$$nbpON = fN \times (nbVSS)$$

$$nbVSS = 68.3$$

$$nbpON = 0.075 \times 68.3 = 5.13 \text{ mg/l}$$

Inorganic	Organic	Nonbiodegradable Particulate nbpON	5.1	33.5	137.1	137.1	Particulate	
		Biodegradable Particulate bpON	28.4					
		Biodegradable Soluble bsON		4.4				Soluble
		Nonbiodegradable Soluble(Refractory) nbsON						
		AMMONIA NH4-N	99.2	103.6				
NITRATE &NITRITE NO₃,NO₂	0.0		TN					

EXAMPLE – ESTIMATION OF nbsON

No.	Parameter	unit	Plant Influent	Plant Effluent
10	Total Kjeldhal Nitrogen(TKN)	mg/L	137	91
11	Filtered TKN	mg/L	103.6	81.6
12	Ammonium(NH₄-N)	mg/L	99.2	76.9
13	Nitrate	mg/L		2
14	Nitrite	mg/L		2

$$nbsON \approx 0.02 \times TKN$$

$$nbsON \approx 0.02 \times 137 \approx 2.7$$

Organic	Nonbiodegradable Particulate nbpON	5.1	33.5	137.1	137.1	Particulate
	Biodegradable Particulate bpON	28.4				
	Biodegradable Soluble bsON	1.7	4.4			Soluble
	Nonbiodegradable Soluble(Refractory) nbsON	2.7				
Inorganic	AMMONIA NH4-N	99.2	103.6		0.0	TKN
	NITRATE &NITRITE NO ₃ ,NO ₂					

EXAMPLE – CALCULATION OF PARTICULATE ORGANIC NITROGEN FRACTION(F_{nox}) & AMMONIA FRACTION(F_{na})

$$F_{nox} = \frac{pON}{ON} = \frac{33.5}{37.9} = 0.88$$

$$F_{na} = \frac{NH_4 - N}{tTKN} = \frac{99.2}{137.1} = 0.72$$

Inorganic	99.2	NITRATE & NITRITE NO ₃ , NO ₂	0.0		137.1	137.1	Soluble	
		AMMONIA NH ₄ -N	99.2	103.6				
		Nonbiodegradable Soluble(Refractory) nbsON						2.7
		Biodegradable Soluble bsON						1.7
		Biodegradable Particulate bpON						28.4
Nonbiodegradable Particulate nbpON	5.1							
Organic	37.9					137.1	Particulate	
								TKN
								TN


EXAMPLE – ESTIMATION OF F_{PO_4}

No.	Parameter	unit	Plant Influent	Plant Effluent
8	Total Phosphorus	mg/L	15.8	15.6
9	Orthophosphate (PO₄)	mg/L	32.4	37.4
	PO₄-P	mg/L	10.5	12.1

$$F_{PO_4} = \frac{PO_4 - P}{TP}$$

$$F_{PO_4} = \frac{10.5}{15.8} = 0.66$$

COD,BOD & TSS RELATIONSHIP IN THE EXAMPLE



MISCONCEPTION ON NITROGEN & PHOSPHURUS LIMITS

What is the difference between?

NO_3 and $\text{NO}_3\text{-N}$
 NH_4 and $\text{NH}_4\text{-N}$
 NH_3 and $\text{NH}_3\text{-N}$
 PO_4 and $\text{PO}_4\text{-N}$

MISCONCEPTION ON NITROGEN & PHOSPHURUS LIMITS

There is a misunderstanding in the way the Nitrogen and Phosphorus limits are expressed .

Wastewater test results and effluent quality for Nitrogen and Phosphorus given in standards are expressed in one of the following methods :

- Elemental basis (i.e. $\text{NO}_3\text{-N}$ and $\text{NH}_4\text{-N}$, $\text{PO}_4\text{-P}$).
- Molecular basis (i.e. NO_3 and NH_4 , PO_4).

Parameter	Ratio	Parameter	Ratio
$\text{NO}_3\text{-N} / \text{NO}_3$	0.226	$\text{NO}_3 / \text{NO}_3\text{-N}$	4.429
$\text{NH}_3\text{-N} / \text{NH}_3$	0.824	$\text{NH}_3 / \text{NH}_3\text{-N}$	1.214
$\text{NH}_4\text{-N} / \text{NH}_4$	0.778	$\text{NH}_4 / \text{NH}_4\text{-N}$	1.286
$\text{PO}_4\text{-P} / \text{PO}_4$	0.326	$\text{PO}_4\text{-P} / \text{PO}_4$	3.065

Parameter	Atomic Weight	Molecular Weight
N	14	
O	16	
H	1	
NO_3		62
NH_3		17
NH_4		18
P	31	
PO_4		95

RECOMMENDED TYPICAL FRACTIONS

Name	Fraction Description	Unit	Raw	Settled
F_{bs}	Readily biodegradable (including Acetate)	[gCOD/g of total COD]	0.16	0.27
F_{us}	Non-biodegradable soluble	[gCOD/g of total COD]	0.05	0.08
F_{xsp}	Particulate non-colloidal slowly biodegradable	[gCOD/g of slowly degradable COD]	0.75	0.50
F_{up}	Non-biodegradable particulate	[gCOD/g of total COD]	0.13	0.08
F_{na}	Ammonia	[gNH ₃ -N/gTKN]	0.66	0.75
F_{nox}	Particulate biodegradable organic nitrogen	[gN/g Organic N]	0.50	0.25
F_{nus}	non-biodegradable soluble TKN	[gN/gTKN]	0.02	0.02
F_{po4}	Phosphate	[gPO ₄ -P/gTP]	0.50	0.75
F_{upP}	P:COD ratio for influent non-biodegradable part. COD	[gP/gCOD]	0.011	0.011
F_{upN}	N:COD ratio for non-biodegradable part. COD	[gN/gCOD]	0.035	0.035

HOMework

Estimate COD, N and P fractions for the sampling results given below

No.	Parameter	unit	Plant Influent	Plant Effluent
1	Total COD	mg/L	2220	375
2	Filtered COD(1.2 um glass fiber filter)	mg/L	837	214
3	Filtered/flocculated COD (0.45 um filter)	mg/L	674	
4	BOD ₅	mg/L	1087	108
5	Filtered BOD ₅ (1.2 um glass fiber filter)	mg/L	490	46
6	TSS	mg/L	925	115
7	VSS	mg/L	733	96
8	Total Phosphorus	mg/L	22	16
9	Orthophosphate	mg/L	42	17
10	Total Kjeldhal Nitrogen(TKN)	mg/L	179	127
11	Filtered TKN	mg/L	130	113
12	Ammonia	mg/L	106	102
13	Nitrate	mg/L		
14	Nitrite	mg/L		
15	Alkalinity as CaCO ₃	mg/L	779	904

SWIM-H2020 SM

For further information

Website

www.swim-h2020.eu

E: info@swim-h2020.eu

LinkedIn Page

[SWIM-H2020 SM LinkedIn](#)

Facebook Page

[SWIM-H2020 SM Facebook](#)

SWIM and Horizon 2020 Support Mechanism

Working for a Sustainable Mediterranean, Caring for our Future

Thank you for your attention.

This Project is funded by the European Union





umweltbundesamt®


ATKINS

Appendix

FLOCCULATED & FILTERED COD(ffCOD) ANALYSIS

- Procedure for filtered & flocculated COD (ffCOD) test :
 - ❑ 1 mL of 100 g/L zinc sulfate solution is added to 100 mL of wastewater
 - ❑ The sample is then mixed vigorously for approximately 1 minute
 - ❑ The sample pH is adjusted to approximately 10.5 using 6 M sodium hydroxide solution(NaOH).
 - ❑ The sample then is allowed to settle, and a sample of the supernatant is withdrawn
 - ❑ The supernatant sample is filtered using a 0.45 μm membrane filter, and the filtrate COD is analyzed.






REFERENCES

1. Methods for Wastewater Characterization in Activated Sludge Modeling, WERF
2. Nutrient Control Design Manual, EPA, August 2010
3. Wastewater Engineering Treatment & Reuse, Metcalf & Eddy, 2004
4. Standard Methods for Wastewater
5. User Manual for BioWin 3., EnviroSim Associates Ltd.

WHY 5 DAY BOD?



STANDARD METHODS FOR EXAMINATION OF WATER & WASTEWATER

